



POTVRDA O TIPNOM ODOBRENJU
TYPE APPROVAL CERTIFICATE

Br / No 01-007991/015286

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju pomorskih brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.

This is to certify that this product on the basis of the Rules for the classification of sea-going ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:

TYPE AND DESCRIPTION OF PRODUCT: "PROTUPOŽARNA VRATA KLASE B-15"
"FIRE-RESISTING DOOR B-15 CLASS"

Vrata su izrađena od čeličnog lima debljine 0,7 mm. Izolacijski materijal je kamena vuna "TERVOL BS-15", debljine 38,6 mm, gustoće 150 kg/m³.

The door is manufactured from steel plate, thickness of 0.7 mm. The insulating material is 38.6 mm thick rock wool "TERVOL BS-15" with density 150 kg/m³.

PROIZVOĐAČ:
MANUFACTURER:



PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:
THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za klasifikaciju pomorskih brodova, Dio 17. – Protupožarna zaštita; Međunarodna Konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama; IMO FTP Kodeks; IMO Rezolucija A.754(18).

Rules for the Classification of Sea-Going Ships, Part 17 – Fire protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended; IMO FTP Code; IMO Resolution A.754(18).

PODRUČJE PRIMJENE/POSEBNI GRANIČNI UVJETI:
FIELD OF APPLICATION/SPECIAL OPERATIONAL LIMITS:

Protupožarna zaštita klase B-15 na brodovima.
B-15 class fire protection on ships.

ODOBRENJE VRIJEDI DO: 2013-07-10
APPROVAL IS VALID UNTIL:

UZ UVJETE NAVEDENE NA POLEĐINI
SUBJECT TO CONDITION OVERLEAF

Mjesto i datum Split, 2009-07-09
 Place and date

M.P.
 (Seal)

.....
 Goran Begović, dipl.ing.

Odobrenje je valjano ako je ovaj proizvod izveden prema slijedećoj dokumentaciji:
The approval is valid if this product is manufactured in accordance with the following documentation:

Protupožarna vrata klase B-15 konstruirana su prema nacrtu br. 0-9008.

Ispitivanje u skladu s IMO Rezolucijom A.754(18) izvršeno je u Zavod za gradbeništvo Slovenije, Požarni laboratorij, Ljubljana. Rezultati ispitivanja navedeni su u izvješću o ispitivanju br. P 3/01-530-3, od 15. ožujka 2000.

Fire-resisting door B-15 class, constructed in accordance with the drawing No.0-9008.

The testing in accordance with IMO Resolution A.754(18) have been carried out in Slovenian National Building and Civil Engineering Institute, Fire Laboratory, Ljubljana. The testing results have been stated in the Test Report No. P 3/01-530-3, dated 15th March 2000.

Ovo odobrenje ne isključuje zahtjev za nadzorom tijekom izradbe proizvoda kod proizvođača, u skladu s gore navedenim Pravilima.
This approval does not eliminate the need for inspection during manufacturing of the product into manufacturers shop in compliance with a.m. Rules.

Raščlana

17.02.04.00

Zamjenjuje potvrdu

01-004547