



**POTVRDA O TIPNOM ODOBRENJU**  
**TYPE APPROVAL CERTIFICATE**

Br / No 01-009206/016246

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.  
 This is to certify that this product on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

**TIP I OPIS PROIZVODA:**

TYPE AND DESCRIPTION OF PRODUCT:

**PRENOSIVI SLOG ZA PJENU TIP 200**

**PORTABLE FOAM APPLICATOR UNIT TYPE 200**

Prenosivi slog za pjenu, za priključenje na glavni sustav gašenja požara, sastoji se od:

- ručne mlaznice pjene tip "MTP-200";
- mješača pjene tip "PMP 200";
- dvije posude koncentrata pjene STHAMEX F-15 zapremine 20 l;
- dvije protupožarne cijevi duljine 15 m s fiksnim spojnicama ND 52 na obje strane;
- gumene cijevi za priključenje posude na mješač.

Portable foam applicator unit, for connection to the fire main, consisting of:

- air-foam nozzle type "MTP-200";
- in-line inductor type "PMP 200";
- two portable tanks each containing 20 l of STHAMEX F-15 foam-making liquid;
- two fire hoses 15 m length with fixed couplings ND 52 on each end;
- pick-up tube for connection of the in-line inductor to the portable tank.

**PROIZVOĐAČ:**  
 MANUFACTURER:



**KOMPAS NOVA d.o.o.**  
 Milutina Barača 58, 51000 RIJEKA  
 HRVATSKA • CROATIA

**PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:**  
 THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

**Pravila za klasifikaciju brodova, Dio 17. - Protupožarna zaštita; Međunarodna konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama.**

*Rules for the classification of ships, Part 17 - Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.*

**PODRUČJE PRIMJENE/POSEBNI GRANIČNI UVJETI:**  
 FIELD OF APPLICATION/SPECIAL OPERATIONAL LIMITS:

**Protupožarna oprema za gašenje požara na brodovima.**  
**Tlak na ulazu mora biti najmanje 0,2 MPa.**

*Fire extinguishing equipment on ships.*  
*Inlet pressure at least 0.2 MPa.*

**ODOBRENJE VRIJEDI DO: 2013-12-31**  
 APPROVAL IS VALID UNTIL:

**UZ UVJETE NAVEDENE NA POLEĐINI**  
 SUBJECT TO CONDITION OVERLEAF

Mjesto i datum ..... **Split, 2012-02-20** .....  
 Place and date

M.P.  
 (Seal)

.....  
 Goran Begović, dipl.ing.

**Odobrenje je valjano ako je ovaj proizvod izveden prema slijedećoj dokumentaciji:**  
*The approval is valid if this product is manufactured in accordance with the following documentation:*

**Mlaznica za tešku pjenu tip “MTP-200”, br. nacрта K-110 (6 listova).**  
**Prenosivi mješač pjene tip “PMP 200”, br. nacрта K-210 (28 listova).**  
**Izvjestaj o tipnom ispitivanju od 06. rujna 2007.**

*Air-foam nozzle type “MTP-200”, drawing No. K-110 (6 sheets).*  
*In-line inductor type “PMP 200”, drawing No. K-210 (28 sheets).*  
*Testing report dated 06<sup>th</sup> September 2007.*

**Ovo odobrenje ne isključuje zahtjev za nadzorom tijekom izradbe proizvoda kod proizvođača, u skladu s gore navedenim Pravilima.**  
*This approval does not eliminate the need for inspection during manufacturing of the product into manufacturers shop in compliance with a.m. Rules.*

**Raščlana**

17.20.00.00

**Zamjenjuje potvrdu**

01-008205