



POTVRDA O TIPNOM ODOBRENJU
TYPE APPROVAL CERTIFICATE

Br / No 01-009207/016246

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.
 This is to certify that this product on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:

TYPE AND DESCRIPTION OF PRODUCT:

PRENOSIVI SLOG ZA PJENU TIP 400

PORTABLE FOAM APPLICATOR UNIT TYPE 400

Prenosivi slog za pjenu, za priključenje na glavni sustav gašenja požara, sastoji se od:

- ručne mlaznice pjene tip "MTP-400";
- mješača pjene tip "PMP 400";
- dvije posude koncentrata pjene STHAMEX F-15 zapremine 20 l;
- dvije protupožarne cijevi duljine 15 m s fiksnim spojnicama ND 52 na obje strane;
- gumene cijevi za priključenje posude na mješač.

Portable foam applicator unit, for connection to the fire main, consisting of:

- air-foam nozzle type "MTP-400";
- in-line inductor type "PMP 400";
- two portable tanks each containing 20 l of STHAMEX F-15 foam-making liquid;
- two fire hoses 15 m length with fixed couplings ND 52 on each end;
- pick-up tube for connection of the in-line inductor to the portable tank.

PROIZVOĐAČ:
 MANUFACTURER:



KOMPAS NOVA d.o.o.
 Milutina Barača 58, 51000 RIJEKA
 HRVATSKA • CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:
 THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za klasifikaciju brodova, Dio 17. - Protupožarna zaštita; Međunarodna konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama.

Rules for the classification of ships, Part 17 - Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.

PODRUČJE PRIMJENE/POSEBNI GRANIČNI UVJETI:
 FIELD OF APPLICATION/SPECIAL OPERATIONAL LIMITS:

Protupožarna oprema za gašenje požara na brodovima.
Tlak na ulazu mora biti najmanje 0,1 MPa.

Fire extinguishing equipment on ships.
Inlet pressure at least 0.1 MPa.

ODOBRENJE VRIJEDI DO: 2013-12-31
 APPROVAL IS VALID UNTIL:

UZ UVJETE NAVEDENE NA POLEĐINI
 SUBJECT TO CONDITION OVERLEAF

Mjesto i datum Split, 2012-02-20
 Place and date

M.P.
 (Seal)

Goran Begović, dipl.ing.

Odobrenje je valjano ako je ovaj proizvod izveden prema slijedećoj dokumentaciji:
The approval is valid if this product is manufactured in accordance with the following documentation:

Mlaznica za tešku pjenu tip “MTP-400”, br. nacрта K-120 (6 listova).
Prenosivi mješač pjene tip “PMP 400”, br. nacрта K-210 (28 listova).
Izvjestaj o tipnom ispitivanju od 06. rujna 2007.

Air-foam nozzle type “MTP-400”, drawing No. K-120 (6 sheets).
In-line inductor type “PMP 400”, drawing No. K-210 (28 sheets).
Testing report dated 06th September 2007.

Ovo odobrenje ne isključuje zahtjev za nadzorom tijekom izradbe proizvoda kod proizvođača, u skladu s gore navedenim Pravilima.
This approval does not eliminate the need for inspection during manufacturing of the product into manufacturers shop in compliance with a.m. Rules.

Raččlana

17.20.00.00

Zamjenjuje potvrdu

01-008206