

**POTVRDA O TIPNOM ODOBRENJU**
TYPE APPROVAL CERTIFICATE

Br /No 01-010837/017458

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:

TYPE AND DESCRIPTION OF PRODUCT:

NAPRAVA ZA GAŠENJE POŽARA PRAHOM S50*DRY POWDER FIRE EXTINGUISHER S50***PROIZVOĐAČ:**
MANUFACTURER**PASTOR-TVA d.d.**Novačka 2
10437 RAKITJE

HRVATSKA • CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za klasifikaciju brodova, Dio 17. - Protupožarna zaštita; Međunarodna konvencija o zaštiti ljudskog života na moru SOLAS 1974, s izmjenama.*Rules for the classification of ships, Part 17- Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended.***DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEĐINI.**

FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRIJEDI DO:
APPROVAL IS VALID UNTIL:

2019-03-27

Mjesto i datum:
Place and date:

Split, 2015-05-26

M.P.
(Seal)

Marinko Popović, dipl.ing.

NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

PODROBNJI OPIS PROIZVODA:

DETAILED PRODUCT DESCRIPTION:

Prijevozna naprava za gašenje požara prahom (ABC prah) s ugrađenom bočicom CO₂ kao sredstvom aktivacije.

Dimenzije (širina/visina): 555/1100 mm

Količina sredstva za gašenje: 50 kg

Masa naprave: 84 kg

Temperaturno područje djelovanja naprave: -20°C do + 60°C

Transportable dry powder (ABC powder) fire extinguisher with built-in CO₂ cartridge propellant.

Dimensions (width/height): 555/1100 mm

Extinguishing agent quantity: 50 kg

Fire extinguisher mass: 84kg

Operation temperature range: -20°C to + 60°C

PODRUČJE PRIMJENE / POSEBNI GRANIČNI UVJETI:

APPLICATION / LIMITATIONS:

Gašenje A, B i C vrste požara na brodovima.

Extinguishing of class A, B and C fire on ships.

DOKUMENTACIJA ZA TIPNO ODOBRENJE:

TYPE APPROVAL DOCUMENTATION:

Nacrt "APARAT S50MED" oznake 507035 MED od 06.2011.

Izješće o ispitivanju br. 511-01-80-657-19/03.

Drawing "APARAT S50MED" No. 507035 MED dated June 2011.

Test report No. 511-01-80-657-19/03.

OZNAČAVANJE PROIZVODA:

MARKING OF PRODUCT:

Svaka pojedina naprava mora imati slijedeće oznake: ime proizvođača, tip proizvoda i datum proizvodnje (mjesec i godina).

Each fire extinguisher shall be marked with: manufacturer's name, type of product and date of manufacture (month and year).

UVJETI ZA CERTIFIKACIJU:

CONDITIONS FOR CERTIFICATION:

Hrvatski registar brodova izdaje posebnu potvrdu o nadzoru za svaku pojedinu proizvedenu količinu (HRB obrazac QF-PB-15).

Croatian Register of Shipping shall issue particular certificate on supervision for each manufactured quantity (CRS form QF-PB-15).

Raččlana

17.04.02.00

Zamjenjuje potvrdu

01-008758