CROATIAN REGISTER OF SHIPPING



Certificate No.

01-013239/019795

TYPE APPROVAL CERTIFICATE

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TYPE AND DESCRIPTION OF PRODUCT:

PORTABLE POWDER FIRE EXTINGUISHER, Capacity 12 kg Type 14172

MANUFACTURER:

A.B.S. s.r.l.

Viale Lombardia, 310 20861 Brugherio (MB) ITALY

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Rules for the classification of ships, Part 17-Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended; IMO Resolution A.951(23).

 ${\bf FURTHER\ DETAILS\ OF\ THE\ PRODUCT\ AND\ CONDITIONS\ FOR\ CERTIFICATION\ ARE\ GIVEN\ OVERLEAF.}$

APPROVAL IS VALID UNTIL: 2023-03-14

Place and date: Split, 2019-03-14 Seal

Marinko Popović, dipl.ing.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

QF-PTO-01 1/2 2019-03



Certificate No.

01-013239/019795

DETAILED PRODUCT DESCRIPTION:

Portable powder fire extinguisher with stored pressure, Type 14172

Cylinder material: steel DD12 EN 10111

Cylinder dimensions (external diameter/height): 190/545 mm

Cylinder capacity: 13,4 l Valve body material: brass

Extinguishing agent type and quantity: FUREX ABC 40, 12kg

Operating temperature range: -30°C to + 60°C Fire rating according to EN 3-7: 55A - 233B - C

APPLICATION / LIMITATIONS:

Extinguishing of class A, B and C fires on ships.

TYPE APPROVAL DOCUMENTATION:

Test report No. 3648-2005 dated 11.10.2005. issued by Istituto Masini S.r.l.

Drawings attached to the Test report:

No. 13172 dated 08.05.2003., no. 27503 dated 29.10.2004., no. 21810 dated 09.12.2002., no. 21521 dated 18.12.2002., no. 21615 dated 28.04.2005., no. 21709 dated 08.05.2003. and no. 21001 dated 03.12.2001.

MARKING OF PRODUCT:

Each fire extinguisher shall be marked with: manufacturer's name, type of product and date of manufacture (month and year).

CONDITIONS FOR CERTIFICATION:

-