CROATIAN REGISTER OF SHIPPING



Certificate No.

01-013240/019795

TYPE APPROVAL CERTIFICATE

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products.

TYPE AND DESCRIPTION OF PRODUCT:

PORTABLE FOAM FIRE EXTINGUISHER, Capacity 9 l Type 14396_45

MANUFACTURER:

A.B.S. s.r.l.

Viale Lombardia, 310 20861 Brugherio (MB) ITALY

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Rules for the classification of ships, Part 17-Fire Protection; International Convention for the Safety of Life at Sea SOLAS 1974, as amended; IMO Resolution A.951(23).

 ${\bf FURTHER\ DETAILS\ OF\ THE\ PRODUCT\ AND\ CONDITIONS\ FOR\ CERTIFICATION\ ARE\ GIVEN\ OVERLEAF.}$

APPROVAL IS VALID UNTIL: 2023-03-14

Place and date: Split, 2019-03-14 Seal

Marinko Popović, dipl.ing.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

QF-PTO-01 1/2 2019-03



Certificate No.

01-013240/019795

DETAILED PRODUCT DESCRIPTION:

Portable foam fire extinguisher with stored pressure, Type 14396_45

Cylinder material: steel DC01 EN10130

Cylinder dimensions (external diameter/height): 190/552 mm

Valve body material: aluminium

Cylinder capacity: 13,2 l

Type and extinguishing agent quantity: Sealfire®ABF 26 %, 91

Operating temperature range: 0° C to + 60° C Fire rating according to EN 3-7: 55A - 233B - 75F

APPLICATION / LIMITATIONS:

Extinguishing of class A, B and F fires on ships.

TYPE APPROVAL DOCUMENTATION:

Test report No. 0013\DC\EST\17 dated 14.11.2017. issued by CSI S.p.a.

Drawings attached to the Test report:

No. 13396_45 rev. A dated 01.02.2016., no. 27507_45 dated 20.06.2017., no. 21821_45 rev. 3 dated 23.6.2009., no. 21617 dated 07.02.2013, no. 21709_45 dated 08.05.2003, no. 21534 rev. A dated 07.02.2013., no. 21032 dated 19.3.2007. and no. 20052 dated 7.2.2013.

MARKING OF PRODUCT:

Each fire extinguisher shall be marked with: manufacturer's name, type of product and date of manufacture (month and year).

CONDITIONS FOR CERTIFICATION:

-