



POTVRDA O TIPNOM ODOBRENJU
TYPE APPROVAL CERTIFICATE

Br / No **02-001295/ 022670**

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za tehnički nadzor pomorskih brodova - Dio 1. - Opći propisi - Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.
 This is to certify that this product on the basis of the Rules for technical supervision of sea-going ships - Part 1 - General requirements - Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:
TYPE AND DESCRIPTION OF PRODUCT:

TOP PJENE (bacač voda-pjena)
FOAM MONITOR

Tip
Type **BVP 150**

Tvornička oznaka
Factory identification **414.080**

PROIZVOĐAČ:
MANUFACTURER: **PASTOR INŽENJERING d.d.**
 10437, Rakitje, Novačka 2

HRVATSKA - CROATIA

PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:
THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

Pravila za tehnički nadzor pomorskih brodova, Dio 17, Protupožarna zaštita
Rules for the technical supervision of Sea-Going Ships, Part 17, Fire Protection

Međunarodna Konvencija o sigurnosti života na moru SOLAS 1974, uz izmjene, i FSS kodeks, uz zadnje izmjene, rezolucija MSC. 217(82).
International Convention for the Safety of Life at Sea SOLAS 1974, as amended, and FSS Code, as last amended by resolution MSC. 217(82).

PODRUČJE PRIMJENE/POSEBNI GRANIČNI UVJETI:
FIELD OF APPLICATION/SPECIAL OPERATIONAL LIMITS:

Ugrađeni palubni sustav pjene niske ekspanzije (ne prelazi 12).
Fixed deck low expansion foam system (not exceeding 12).

Radni tlak 10 bara, količina dobave 10000 l/min, domet 88 m.
Working pressure 10 bar, capacity 10000 l/min, throw 88 m.

ODOBRENJE VRIJEDI DO: **2012.12.01.**
APPROVAL IS VALID UNTIL:

UZ UVJETE NAVEDENE NA POLEĐINI
SUBJECT TO CONDITION OVERLEAF

Mjesto i datum Split, 2008.12.01.
Place and date

M.P.
(Seal)

Goran Begović, dipl.ing.