

**POTVRDA O TIPNOM ODOBRENJU**
TYPE APPROVAL CERTIFICATEBr /No **02-002151/023989**

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.

This is to certify that this product, on the basis of the Rules for the classification of ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:

TYPE AND DESCRIPTION OF PRODUCT:

Ventil za CO₂ bocu izvedba
Valve for CO₂ bottle construction

B SP 900.023**C SP 900.022****D SP 900.012****F SP 900.015**PROIZVOĐAČ:
MANUFACTURER:**PASTOR INŽENJERING d.d.**

10437 RAKITJE, Novačka 2

HRVATSKA • CROATIA**PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:**

THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:

HRB: Pravila za klasifikaciju brodova, Dio 17. – Protupožarna zaštita.**CRS: Rules for the classification of ships, Part 17. – Fire protection.****DETALJI O PROIZVODU I UVJETIMA CERTIFIKACIJE DANI SU NA POLEDINI.**

FURTHER DETAILS OF THE PRODUCT AND CONDITIONS FOR CERTIFICATION ARE GIVEN OVERLEAF.

ODOBRENJE VRIJEDI DO: 2020-09-03

APPROVAL IS VALID UNTIL:

Mjesto i datum: Split, 2016-09-16

Place and date:

M.P.

(Seal)

Marinko Popović, dipl.ing.

NAPOMENA: Ova potvrda nije valjana ako se proizvod ili način njegove proizvodnje promijenio u odnosu na tipno ispitani proizvod. Proizvođač treba obavijestiti Hrvatski registar brodova o bilo kojoj izmjeni na proizvodu kako bi ishodio valjanu potvrdu.

NOTE: This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Croatian Register of Shipping of any modification or changes to the product in order to obtain a valid certificate.

PODROBNJI OPIS PROIZVODA:
DETAILED PRODUCT DESCRIPTION:

Izvedba
Construction

B pneumatsko ili ručno otvaranje, sa sigurnosnom membranom u atmosferu

B pneumatic or manual release, with bursting disc to atmosphere

C pneumatsko ili ručno otvaranje, sa sigurnosnom membranom u sabirnu cijev

C pneumatic or manual release, with bursting disc to collection tube

D ručno otvaranje

D manual release

F otvaranje ručnim kolom

F opening by hand wheel

PODRUČJE PRIMJENE / POSEBNI GRANIČNI UVJETI:
APPLICATION / LIMITATIONS:

CO₂ boca faktor punjenja 0,67/izvedba
CO₂ bottle filling ratio 0,67/construction

B SP 900.023

bez ograničenja

without operational limits

C SP 900.022

bez ograničenja

without operational limits

D SP 900.012

za upotrebu na otvorenoj palubi
for use on open deck

F SP 900.015

za upotrebu na otvorenoj palubi
for use on open deck

DOKUMENTACIJA ZA TIPNO ODOBRENJE:
TYPE APPROVAL DOCUMENTATION:

Vidi naše pismo broj 2542/TS/SG/020065/455/DV od 1995-10-18.
See our letter No 2542/TS/SG/020065/455/DV of 18th October 1995.

OZNAČAVANJE PROIZVODA:
MARKING OF PRODUCT:

- | | |
|-----------------------------|------------------------------|
| - oznaka proizvođača | - <i>manufacturer's mark</i> |
| - izvedba | - <i>construction</i> |
| - serijski broj | - <i>serial No.</i> |
| - materijal kućišta | - <i>body material</i> |
| - ispitni tlak | - <i>test pressure</i> |

UVJETI ZA CERTIFIKACIJU:
CONDITIONS FOR CERTIFICATION:

-