

**POTVRDA O TIPNOM ODOBRENJU**
*TYPE APPROVAL CERTIFICATE*Br / No **03-001158/ 030790**

Potvrđuje se da je ovaj proizvod, u skladu s Pravilima za klasifikaciju pomorskih brodova, Dio 1. - Opći propisi, Odjeljak 3. - Tipno odobrenje proizvoda, odobren za ugradnju na brodove i postrojenja pod nadzorom Hrvatskog registra brodova.

This is to certify that this product on the basis of the Rules for the classification of sea-going ships, Part 1 - General requirements, Chapter 3 - Type approval of products, is approved for use on board ships and installations under supervision of the Croatian Register of Shipping.

TIP I OPIS PROIZVODA:*TYPE AND DESCRIPTION OF PRODUCT:***NISKONAPONSKI KOMPAKTNI PREKIDAČI**
*LOW-VOLTAGE MOLDED-CASE CIRCUIT-BREAKERS***E 100, ASM 100, BM 160 N 250, ASM 400,
E 400, ASM 630, N 1000, NH 630, NH 800,
NH 1000, NH 1250****PROIZVOĐAČ:**
*MANUFACTURER:***KONČAR-NISKONAPONSKE SKLOPKE I PREKIDAČI d.o.o.***10000 ZAGREB, Borongajska cesta b.b. - p.p. 209***HRVATSKA - CROATIA****PROIZVOD UDOVOLJAVA SLIJEDEĆIM PRAVILIMA/PROPISIMA:***THE PRODUCT MEETS FOLLOWING RULES/REGULATIONS:*

Hrvatski registar brodova: Pravila za tehnički nadzor pomorskih brodova, Dio 12
Croatian Register of Shipping: Rules for Technical Supervision of Sea-Going Ships, Part 12
IEC 947-1; IEC 947-2

PODRUČJE PRIMJENE/POSEBNI GRANIČNI UVJETI:*FIELD OF APPLICATION/SPECIAL OPERATIONAL LIMITS:*

Uređaji su predviđeni za montažu na ploče, nosače, u ormare i sl.
The devices are intended for installation on boards, pillars, in cubicle and the like.

Udovoljavaju uvjete rada unutrašnjim prostorima u normalnim i tropskim klimatskim uvjetima.
They are intended for indoor application at normal and tropical climate condition.

ODOBRENJE VRIJEDI DO: 2013-02-27
*APPROVAL IS VALID UNTIL:***UZ UVJETE NAVEDENE NA POLEĐINI**
*SUBJECT TO CONDITION OVERLEAF***Mjesto i datum** Split, 2009-02-27
*Place and date***M.P.**
(Seal)

Goran Begović, dipl.ing.

Odobrenje je valjano ako je ovaj proizvod izveden prema slijedećoj dokumentaciji:
The approval is valid if this product is manufactured in accordance with the following documentation:

E 100	-	B23000/A
ASM 100	-	605607/A
BM 160	-	B21110/B
N250	-	B24000
ASM 400	-	608900
E 400	-	B29000
ASM 630	-	B42000
N 1000	-	B40000
NH 1000	-	B42001
NH 1250	-	B40000/A
NH 630	-	Potvrda o sukladnosti br. 30/2089
NH 800	-	Potvrda o sukladnosti br. 30/02076

Napomena: Potvrda je odobrena temeljem izjave u dopisu od 2009-01-15.
Note: Certificate is renewed on the basis of the declaration in letter dated 2009-01-15.

Ovo odobrenje ne isključuje zahtjev za nadzorom tijekom izradbe proizvoda kod proizvođača, u skladu s gore navedenim Pravilima.
This approval does not eliminate the need for inspection during manufacturing of the product into manufacturers shop in compliance with a.m. Rules.

Račlana

12.03.01

Zamjenjuje potvrdu

03-000922/ 030567